


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and SS 25269

CLIENT: Abstracta AB

OBJECT: Abstracta Stitch, 1000*1500. Free standing floor screen with two sided absorption. Total absorbing area = 3,0 m².

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)	
	1/3 octave band	Octave band
50	0,14	
63	0,47	0,4
80	0,56	
100	0,72	
125	0,77	0,8
160	1,04	
200	1,32	
250	1,68	1,7
315	2	
400	2,27	
500	2,57	2,5
630	2,66	
800	2,72	
1000	2,79	2,8
1250	2,78	
1600	2,86	
2000	2,94	3
2500	3,08	
3150	3,1	
4000	3,09	3,1
5000	3,24	

**CONDITIONS**

Date of test: 2013-10-16

Date: 2014-01-20

Object area: 1,5 m²

Reverberation room volume: 200 m³

Test report: 13-137-M2 dated 2013-11-12 (Akustikverkstan AB, Sweden)

Signature: Klas Hagberg